



# Attestation of Conformity

## ISO/IEC, EN & TIA/EIA Screened Class E / Category 6 Permanent Link

**Reichle & De-Massari AG**  
**Binzstrasse 31**  
**CH-8622 Wetzikon, Switzerland**

*Attestation of Conformity No. 100141A*

*This type of Class E / Category 6 Screened Permanent Link has been tested by 3P Third Party Testing and complies with the Class E requirements of the proposed 2nd Editions of ISO/IEC 11801 and CENELEC EN 50173, Category 6 requirements of draft ANSI/TIA/EIA-568-B.1-1, Class D requirements of ISO/IEC 11801 ed. 1.2 and CENELEC EN 50173/A1, and Category 5e requirements of ANSI/TIA/EIA-568-B.1. The Attestation of Conformity is valid for the actually tested permanent link in T568A designation consisting of the following components:*

<i>Cable from Reichle &amp; De-Massari:</i>	<i>Horizontal Cable,</i>	<i>R35060</i>
	<i>Qualification Status:</i>	<i>3P Verified</i>
<i>Conn. Hardw. from Reichle &amp; De-Massari:</i>	<i>Connection Module,</i>	<i>R302372</i>
	<i>RJ 45 Plug from Patch Cord,</i>	<i>R305072</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>

Hoersholm, 13 November 2000

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

Hoersholm, 13 November 2000

*Paul Villien*

Poul Villien  
Coordinating Manager