



Attestation of Conformity

ISO/IEC, EN & TIA/EIA Screened Class D⁺ / Category 5e Four Connector Channel

Reichle & De-Massari AG
Binzstrasse 31
CH-8622 Wetzikon, Switzerland

Attestation of Conformity No. 103391

This type of Class D⁺ / Category 5e screened four connector channel has been tested by 3P Third Party Testing and complies with the Class D:2002 channel requirements of 2nd Edition ISO/IEC 11801 and CENELEC EN 50173-1, and Category 5e channel requirements of ANSI/TIA/EIA-568-B.1. The Attestation of Conformity is valid for the actually tested channel sample in T568A designation consisting of the following components:

<i>Cables from Reichle & de-Massari:</i>	<i>Horisontal Cable, Flexible Cable, Qualification Status:</i>	<i>P/N R35049 P/N 7447 Manufacturer Verified</i>
<i>Conn. Hardw. from Reichle & de-Massari:</i>	<i>Connection Module, Qualification Status:</i>	<i>P/N R925370 having Preformed Inlay Conductors Manufacturer Verified</i>
<i>Patch Cords from Reichle & de-Massari:</i>	<i>2,0 m and 5,0 m Patch Cords, Qualification Status:</i>	<i>P/N R305042 and P/N R305044 Manufacturer Verified</i>

Hoersholm, 11 November 2003

Ole Lambertsen

Ole Lambertsen
Test Responsible

Hoersholm, 11 November 2003

Paul Villien

Poul Villien
Coordinating Manager