



# Attestation of Conformity

## ISO/IEC, EN & TIA/EIA Screened Class D<sup>+</sup> / Category 5e Four Connector Channel

**Reichle & De-Massari AG**  
**Binzstrasse 31**  
**CH-8622 Wetzikon, Switzerland**

### *Attestation of Conformity No. 103388*

*This type of Class D<sup>+</sup> / Category 5e screened four connector channel has been tested by 3P Third Party Testing and complies with the Class D:2002 channel requirements of 2nd Edition ISO/IEC 11801 and CENELEC EN 50173-1, and Category 5e channel requirements of ANSI/TIA/EIA-568-B.1. The Attestation of Conformity is valid for the actually tested channel sample in T568A designation consisting of the following components:*

<i>Cables from Reichle &amp; de-Massari:</i>	<i>Horizontal Cable, Flexible Cable, Qualification Status:</i>	<i>P/N R35052 and P/N R35053 P/N 7447 3P Verified Horizontal Cables and Manufacturer Verified Flexible Cable</i>
<i>Conn. Hardw. from Reichle &amp; de-Massari:</i>	<i>Connection Module, Qualification Status:</i>	<i>P/N R925370 having Preformed Inlay Conductors Manufacturer Verified</i>
<i>Patch Cords from Reichle &amp; de-Massari:</i>	<i>2,0 m and 5,0 m Patch Cords, Qualification Status:</i>	<i>P/N R305042 and P/N R305044 Manufacturer Verified</i>

Hoersholm, 4 November 2003

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

Hoersholm, 4 November 2003

*Paul Villien*

Poul Villien  
Coordinating Manager