



Attestation of Conformity

ISO/IEC, EN & TIA/EIA Unscreened Class E / Category 6 Four Connector Channel

Reichle & De-Massari AG
Binzstrasse 31
CH-8622 Wetzikon, Switzerland

Attestation of Conformity No. 103386

This type of Class E / Category 6 unscreened four connector channel has been tested by 3P Third Party Testing and complies with the Class E channel requirements of 2nd Edition ISO/IEC 11801 and CENELEC EN 50173-1, and the Category 6 channel requirements of ANSI/TIA/EIA-568-B.2-1. The Attestation of Conformity is valid for the actually tested channel sample in T568A designation and consisting of the following components:

<i>Cables from Reichle & de-Massari:</i>	<i>Horizontal Cable,</i>	<i>P/N R35057</i>
	<i>Flexible Cable,</i>	<i>P/N 302804</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Conn. Hardw. from Reichle & de-Massari:</i>	<i>Connection Module,</i>	<i>P/N R302373</i>
		<i>having Preformed Inlay Conductors</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Patch Cords from Reichle & de-Massari:</i>	<i>2,0 m and 5,0 m,</i>	<i>P/N R302312 and P/N R302314</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>

Hoersholm, 30 October 2003

Ole Lambertsen

Ole Lambertsen
Test Responsible

Hoersholm, 30 October 2003

Paul Villien

Poul Villien
Coordinating Manager